IREDELL COUNTY HEALTH DEPARTMENT 4628924992

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Lewis C. Thompson DATE 3-12-81 PERMIT NO. 69

PHONE: Business _____ Home _____

LOCATION 150 W. SR 1438 SR 1450 .7 mi. on left

S. R. No. _____

SUBDIVISION NAME L. N. LOT NO. 254 SECTION OR BLOCK NO. 1

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 5 No. Bathrooms 3


Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area .74 AC.

Character & Porosity of Soil sandy parent material
Percolation Rate 30 mpi
Topography 15-25%
Depth to Water Table 10'+
Rock or other impervious formations Rock @ ~2½'

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

Split system



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Stuart

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Washing machine, dishwasher, kitchen sink go into 500 gal. tank w/ ditch 9'x48" - 16" + stone

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 3-12-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold