4628928146

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR T.E. Shuler DATE 5-5-77 PERMIT NO. 93

PHONE Business 872-4578 Home 872-1702

LOCATION 150 ft on 1439 Lt on 1457 Lt on 1457

SUBDIVISION NAME Lake Norman LOT NO. 263 SECTION OR BLOCK NO. 11 S. R. No.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Washing Machine Yes (✓) No ( )

Sitter Suite Yes (✓) No ( )

Lot Area 2 Acres

Character & Porosity of Soil Clay loam - Loose Soft

Percolation Rate Soil Bound

Topography 12% Slope

Depth to Water Table 10 ft

Rock or other impervious formations None

Size of Tank 1800 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 225 Linear Ft. 250

Depth of Stone in Lines

Water Supply: Individual (✓)

Public ( )

Installed by E.J. Cruse

Plot of System

IMPROVEMENTS PERMIT BY Chas. Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY Chas. Houston DATE 5-31-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold