IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Reese Cook DATE 4-9-75 PERMIT NO. 65

PHONE: Business _____ Home 956-5513

LOCATION 150 west TR on 1438 - TR on 1456 on left TR 1451 on left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 264 SECTION OR BLOCK NO. 11


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre

Character & Porosity of Soil Clay Loam Porosity fair
Percolation Rate 70 MPI
Topography 20% Slope
Depth to Water Table 8' to 10'
Rock or other impervious formations none



Plot of System

Size of Tank 1200 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 14"
Water Supply: Individual (✓)
Public ( )
Will not located at this time

Installed by Charles Griffin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-9-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold