DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Sumner APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 9/17/99
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: Hermanos Rd PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-36"	Brw C/cl m-wSBK	S-SS, SE, FI-FR				w/few	PS
		b	marl SAP/W. Rock	Indur					
		36-45"	Brw CL SAP	w/ W Rock					1.2
		45-48	SAP w/ W. Rock	Indus					to 36"
		A	Marl more Some	Mixed Mineralogy					
2	10/25/04 w/Brady Pit 1	0-4"	Y Brw SCL w/SBK	SS, SP, FR, SE					U
		4-16"	Yel/Brw C ABK/SBK	E, S, VP, Fi-VFi					
		16"-51	CL SAP massive	FR, S, P					
									17/8" Rock
3	10/25/04 Pit 2	0-10"	Old Fill						U
		10-14"	Yel/Brw	SCL w/SBK	SS, SP, SE, FR				
		14"-27"	Yel/Brw C ABK	/SBK, S, VP,	Fi-VFi, Exp				
		27"-66"	CL SAP	massive FR, S, P					
4	10/25/04 Pit 3	0-15	Yel/Brw C ABK/SBK	E, S, VP, Fi-VFi					U
		15-48	CL SAP	massive FR, S, P					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___