FOR ON-SITE WASTEWATER SYSTEM

OWNER: Linda Whicker APPLICANT:

ADDRESS: APPLICATION DATE: DATE EVALUATED: 3/19/04

PROPOSED FACILITY: PROPOSED DESIGN FLOW (.1949): PROPERTY SIZE:

LOCATION OF SITE: Point of View Lot #15 PROPERTY RECORDED:

WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other

EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut

TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-3"	Brw SCL	GR FR					PS
		3-24"	Rd to Rdl Brw C/CL	m-w SBK SS, SP SE, FI FR					
		24-48"	Rd to Rdl Brw C	w/SBK SS, SP SE, FR				w/few	.3+
			SAP	Inclus					
2		0-4"	Brw SCL	GR FR					PS
		4-40"	Rdl Brw C/CL	m-w SBK SS, SP SE, FI FR					
		40-48"	Rdl Brw C	m-w SBK SS, SP SE, FR					.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946):

SITE CLASSIFICATION (.1948):

EVALUATED BY:

OTHER(S) PRESENT: