3:30-4:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # REPAIR PIN # 4628-96-7301 DATE 5-4-10

OWNER or APPLICANT FREDERICK FISCHER PHONE: Business 704-363-0292 Home: 704-528-5089

OWNER or APPLICANT ADDRESS 111 POINT OF VIEW MOORESVILLE NC 28117

LOCATION / DIRECTIONS PERTH, TL FERN HILL C END ON L

SUBDIVISION POINT OF VIEW BLOCK / SECTION LOT # 2 LOT AREA DESIGN FLOW 480GPD L.T.A.R. .3

Septic Tank EX. Gallons: STB Date

Pump Tank T250 Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 4 Linear Feet 160'

Trench Width 24-36" Max. Trench Bottom Depth * 48" * Gravel Depth SAND

☐ New System ☒ Repair ☐ Expansion System Type I II III IV V VI

System Description:

Repair System Description: GRAVITY PANEL BLOCK

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions 1) REPAIR AREA VERY LIMITED 2) SHOULD BE ROOM FOR 160' OF GRAVITY PANEL BLOCK 3) USE TRENCH BOTTOM OF 48" TO GET INTO .35/.4 SOILS 4) NEW D-BOX TO BE SET W/ 7 OUTLETS

INITIAL SITE SKETCH

1"=50'

POINT OF VIEW

100'

GARAGE

DRIVE WAY

Comments / Conditions 5) MUST BE 5' FROM DECK 6) DRAIN LINES MUST BE 10' FROM PROP LINE 7) SUPPLY LINES CAN GO 5' FROM PROP LINES 8) USE SPEED LEVELERS IN D-BOX 4th line checked 6/4/2010 MD

AS BUILT SKETCH

Everything else checked by BA

NOTE - IF SYSTEM EVER NEEDS REPAIR AGAIN DRIVEWAY NEEDS TO BE REWORKED OR PRETREATMENT MAY NEED TO BE USED

343'

109'

LAKE NORMAN

110'

50'

EX 67'

EX 67'

EX 67'

405'

EXISTING TANK

NEW D-BOX

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *IMPROVEMENT PERMIT w / site plan not valid without expiration.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 5/11/10

Improvement Permit by: REHR Date 5-4-10

Authorization to Construct by: REHR Date 5-4-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Wayne Blount RS

Operation Permit by: Date: 6/4/2010

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant