...ISION OF ENVIRONMENTAL HEALTH
...N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Miller-McCormick Inv. APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 7-2-04
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 460 gpd PROPERTY SIZE: _____
LOCATION OF SITE: Lot 3 Fernview PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-5	gr brn sdl	fr sssp					.3
		5-19	mfsbkrc	fr sssp somp					
		19-58	(Bc) wk fsbk yrcl	fr sssp somp common mic sop					
2	6-8% S	0-33	wk-gr fsbk rdcl	fr sssp somp					.3
		33-58 (Bc)	wk fsbk rd L	fr sssp common mic sop					
3		0-3	gr brn sl cbl fri						.3
		3-27	mfsbkrcl	fr sssp somp					
		27-46	(Bc) wk fsbk yrcl	fr sssp common mic sop					
		46-60	massive fsL	somp fr sssp wp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Pm 25% Red	Pm 25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: [signature]
OTHER(S) PRESENT: Nick Miller

NOTES:

1. THIS PROPERT
2. AREA DETERM
3. CP DENOTES
4. UNDERGROUNI
5. NO GRID MON
6. ALL LOTS TO (ALONG ALL S
7. ZONING – RR SETBACKS FI R S
8. DATE SURVEY
9. OWNERS: MILI 116 MOC PHC
10. AREA TO BE
11. TOTAL NUME
12. AREA OF SM
13. PROPERTY I EASEMENTS
14. AS OF THE REPRESENTE INSPECTED (HEALTH DEP ASSURANCE

MINOR