IREDELL COUNTY HEALTH DEPARTMENT 4628-97-0094

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Grant Weldy DATE 8-7-87 PERMIT NO. 5178

PHONE: Business _____ Home _____

LOCATION 1303 N. R 1300 attend on left

_____ S. R. No. _____

SUBDIVISION NAME Point of View LOT NO. 12 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3½


Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20000 Sq Ft

Character & Porosity of Soil AREA of DRAINfield clay
Percolation Rate 2.4
Topography 8-15%
Depth to Water Table 44
Rock or other impervious formations none obs.

1000 gal pump tank

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. _____ Linear Ft. 200'
Depth of Stone in Lines 16" T&J panels

Water Supply: Individual ( )
Public ( )

Installed by Eddie Younts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Tanks & panels installed & inspected 8-7-87. Alarm to be installed & checked yet.

Alarm checked Aug 17, '87 & found to be working ORA.

CERTIFICATE OF COMPLETION BY OK Hunnicutt, RS. DATE Aug 17, '87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold