IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ed Crowell DATE 4-12-77 PERMIT NO. 54

PHONE: Business _____ Home 535-0279

LOCATION 1203 Tilley 1500 West

S. R. No. _____

SUBDIVISION NAME Parkbrook LOT NO. 12 SECTION OR BLOCK NO. 25

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 2 acre


Character & Porosity of Soil Clay loam

Percolation Rate 50 X 6 ins

Topography Slope

Depth to Water Table 4 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 45 Linear Ft. 250'

Depth of Stone in Lines 24"

Water Supply: Individual (✓)

Public ( )

Installed by E. J. Cain

IMPROVEMENTS PERMIT BY [signature]

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 4-27-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold