IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Everette Hoke DATE 6-25-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION E. Monbo Rd #1328 to Bethel Church. Tr. on 1402. Bear to R. Near Park entrance. T.R. Near end of Rd. House at End. S. R. No. _____

SUBDIVISION NAME Old Homestead #2 LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 sq ft +

Character & Porosity of Soil _____
Percolation Rate No Perk Test made
Topography Steep Slope to Lake Low
Depth to Water Table _____
Rock or other impervious formations Some Shale rock in bottom



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 760 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlu Lackey

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Building Permit issued 2-9-73.
Mr Hoke has Permission from Mr Henry Trentman To Go Closer than 10' to Property line.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6-25-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold