IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kent Morris DATE 8-31-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Perth Rd at Troutman. T.R. on 1321 - T.R. on 1401 T.R. at Sunset Point Sign - T.R. 1st Rd. Trailer on r. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. 133 SECTION OR BLOCK NO. 17

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Lake
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 20 000 sq ft +.



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank.

IMPROVEMENTS PERMIT BY _____

COMMENTS: House to be built on lot later. Back end of tank dep. Well line to be put over back hole for service purposes.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8-31-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold