3 of

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 (a) MOORESVILLE 704-664-5281

R WEBB 980-0822

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 152309 PIN # 4629494802 DATE 4-9-09

OWNER or APPLICANT DERECK OSBORNE BUILDERS PHONE: Business 704-902-3084 Home: 704-871-8787

OWNER or APPLICANT ADDRESS PO BOX 1783 Statesville NC 28687

LOCATION / DIRECTIONS State Park Rd (L) Wildlife (R) Maple View (L) DEER RUN (R) EAGLE CHASE IN CUL-DE-SAC

SUBDIVISION Wildlife Bay BLOCK / SECTION LOT # 52 LOT AREA 1.184 DESIGN FLOW 480 L.T.A.R. .3

Septic Tank 1000 Gallons: STB Date

Pump Tank 1000 Gallons: PT Date

Pump Make Model Serial #

Nitrification Field No Fields No Lines 6 Linear Feet 400'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: PUMP 25'/1 PROVIDE

Repair System Description: LP 50'/1 PROVIDE

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

(1) House & OFFSITE surveyed completely (2) System FLAGGED OUT ENTIRELY (3) USE pressure manifold (4) CALL Prior to installation for pump sizing & system specs if necessary (5) Maintain setbacks

Comments / Conditions

Surveyor said elevation is 40' + tanks & w-line bed should be x 50'. Supply line is estimated at 1800' USE SB 30 tops. use splash pads

INITIAL SITE SKETCH

SEE ATTACHED SYSTEM DESIGN BY LARRY CAUDLE, R.S.

AS BUILT SKETCH

LINE 1- 4= 17 Chambers
Line 5- 6 = 16 Chambers

The location of the proposed sunroom addition does not appear to impact the existing septic system. **NOTE:

REHS

Date: 4-7-11

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 7-21-09

Improvement Permit by: Date 4-9-09

Authorization to Construct by: Date 4-9-09

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Gunter Grading

Operation Permit by: Date: 2-18-11

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant