IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dr. Lonier Osburn DATE 5/27/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 215, T.R. on Peach Ch Rd, T.R. on State Park Rd (#1322), T.R. on Pinnacle Point (1405), last house on RT S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay Loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	70ml Tube
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	slope to Lake
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	deep
			Rock or other impervious formations	possible

Lot Area 125X150



Plot of System

Size of Tank ~~1000~~ 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public (✓)

Installed by Sam Osteen

IMPROVEMENTS PERMIT BY _____

COMMENTS: Last section of system (about 10') was in sandstone type material.

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 5/27/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold