IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ray Freyer DATE 4/14/78 PERMIT NO.

PHONE: Business Home

LOCATION Sunset Point Lake Norman

S. R. No.

SUBDIVISION NAME Sunset Point LOT NO. 117 SECTION OR BLOCK NO. 17

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 0.63 acre


Character & Porosity of Soil

Percolation Rate

Topography Slope to lake Low

Depth to Water Table

Rock or other impervious formations None



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz Son

IMPROVEMENTS PERMIT BY

COMMENTS: No Well on this Property at this time. When Well is Put in keep it More than 50' from Septic Tank & lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4/14/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold