IREDELL COUNTY HEALTH DEPARTMENT

04303

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR D.C. Chandler / Dave DeRamus DATE 04-03-86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Morrison Farm Rd, off Duke Power State Park Rd, Rt. on April Lane T.L. on 2nd Dirt St., T-L. on 2nd Drive, Bear R to end S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 102 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area .96 Acre

Character & Porosity of Soil Prev. suitable

Percolation Rate 0.5 gal/ft²/day

Topography 2-6% Slope

Depth to Water Table 10'+

Rock or other impervious formations none

T+J Panel System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 300 Linear Ft. 150


Depth of ~~Stone~~ Sand in Lines 12"

Water Supply: Individual (✓)

Public ( )

16" T+J Panels in 2' trench

Installed by Julian Bowles



Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Lower line 50'+ from high water mark. Keep well At least 50' from septic tank system

CERTIFICATE OF COMPLETION BY Jerry L Pierce DATE 04-03-86

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold