IREDELL COUNTY HEALTH DEPARTMENT

Permit Voids previously issued permit dated 5-20-04

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 119393 PIN# 4629-53-7099 DATE 12/23/04

OWNER OR CONTRACTOR David Woodard PHONE: Business (704) 902-8157 Home (704) 538-0403

ADDRESS 130 Hampton's Cove Rd Troutman, N.C. 28166

LOCATION State Park Rd, ⓒ Morrison Farm Rd, ⓑ [redacted] APRIL RD, ⓐ WENDWOOD RD

SUBDIVISION Hawkes Bay BLOCK / SECTION ____ LOT 40 LOT AREA 1.6 Ac. SITE CLASS. ES DESIGN FLOW 360' L.T.A.R. .30 gpd/ft²

Septic Tank: 1000 Gallons; STB 100' Date 3-15-05

Pump Tank: 1000 Gallons; PT 2 Hardwood Date 3-15-05

Pump Make: ZOELLER Model N-267 Serial No. ____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 300

No. Lines 4 ENDS Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, (III), IV, V, VI

System Description: Pump & 25% Reduction

Repair System Description: LP-PP65 50% Red

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms ____ No. Employees ____

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

Pressure Manifold

(O Keep Septic Tanks 100 Ft From well)

150 Ft 2" Sch 40

Repair

INITIAL SITE SKETCH

50'

35'

Pump Tank

Septic Tank

44'

35'

Gravel

32' House

Well

105'

Repair Area

100 Ft

Neighbor's septic

1" = 50 Ft

Wind wood Lane

Comments:/Conditions:

1½ WELL TO TANKS 76

V'D 3 LINES 5-10-05 LC 76

V'D LAST LINE TANKS & SETBACKS 5-19-05 LC 76

NEEDS ELECTRICIAN 76

AS BUILT SKETCH

BUILDER Approved Septic Changes

Lake Norman

50 Ft

50 Ft

357' PL

352' PL

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: David Woodard date 1-10-05 Installed by: L & L CONST

Improvement Permit by: William O. Johnson date 12/23/04 Operation Permit by: [signature] date 5-19-05

Authorization to Construct by: William O. Johnson date 12/23/04 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK