DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 123047
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Applicant
OWNER: Kenneth Stovesand APPLICATION DATE 7/26/04 4629-58-9769
ADDRESS: 9617 RUMSWICK COURT CHARLOTTE, NC 28269 DATE EVALUATED: 8-11-04
PROPOSED FACILITY: 3 BR Home PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .57 ± 14238 sq ft
LOCATION OF SITE: Wildlife BAY LOT 29 + OFFSITE JOA PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☒ Other Community
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4% L	0-6"	scl wk gr	fr ns sp nep					PS .3
		6-48"	c med sbk	fi s p sep					
			sp incl ossl 5%						
2	4% L	0-6"	scl wk gr	fr ns sp nep					PS .3
		6-48"	c med sbk	fi s p sep					
3	4% L	0-6"	scl wk gr	fr ns sp nep					PS .3
		6-48"	c med sbk	fi s p sep					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	OFF SITE PUMP SYSTEM	OFF SITE UP FLOW
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. LODI
OTHER(S) PRESENT: LEONARD WIGGINS

COMMENTS: _____