IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dr H. C. Kuttch DATE 8-13-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Potts Rd at Troutman. T.R. on 1321. T.R. on 1434 (Penicillin Point.) House on R. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Lake
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 20,000 +



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Eddie Young

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8-13-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold