IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George S. McLelland DATE 12/22/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Perth Rd to State Park Rd #1321. T.R. on Dirt Rd just before 1434 (Pennellin Pt. Rd) Trailer on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 83 SECTION OR BLOCK NO. 17

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes ( )	No ( )	well
Site Suitable	Yes ( )	No ( )	

Lot Area 20 000 sq ft


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slope to Lake Low

Depth to Water Table _____

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

well next door

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/22/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold