IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Reavis DATE 6-23-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION T.R. 1st Dirt road below Sunset Point Rd. on Lake Norman S. R. No. _____


SUBDIVISION NAME _____ LOT NO. 91 SECTION OR BLOCK NO. 17

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Lake
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 0.81 acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 540 Linear Ft. 216
Depth of Stone in Lines 15" 7
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lines should not be Driven over

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold