05728

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR JOHN DAVID MONTGOMERY DATE 11-6-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Morrison Farm Rd. off Duke Power State Park Rd. - T.R. on Mary's Lane go to fork, bear R - road is on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

~~OWNER~~ ~~NEW~~

House (4) Mobile Home (4) Business ( ) Other Manufactured Home later.

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (4)

Auto. Dishwasher Yes (4) No ( )

Auto. Wash. Machine Yes (4) No ( )

Site Suitable Yes (4) No ( )

Character & Porosity of Soil Gravelly Suitable

Percolation Rate 4 Gal. Per. Ft.


Topography G-10% 0-2%

Depth to Water Table 10'+

Rock or other impervious formations none observed.

Lot Area 8 Acres.

___ Basement with Plumbing ___ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 300 Linear Ft. 150

Depth of Stone in Lines _____

Water Supply: Individual (4)

Public ( )

T+J Panel system (16").

Installed by AAA Enterprises

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Kelly Sleeks, R.S.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 11-6-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold