IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Iredell Fish And Game Club DATE 5-25-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION OFF OF State Park Road

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other Clubhouse

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____

Character & Porosity of Soil _____
Percolation Rate _____
Topography Repair
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines Shown on Sketch
Sq. Ft. 1200 Linear Ft. 480
Depth of Stone in Lines 15"
Water Supply: Individual (✓)
Public ( )

Installed by Self

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Put in on Sat. 5-25 and Sunday 5-26.
Only Part of installation was inspected.
Henry Sigmon, assisted in installation

CERTIFICATE OF COMPLETION BY E. A. S. DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold