HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Crescent Resources OWNER:__AGENT:__ PHONE:
ADDRESS: APPLICATION DATE:__DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: Sec 17 Lot 855
WATER SUPPLY: On-Site Well___Comm. Well___Public___Other___EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear 5%	0 to 18	L GR		PS	PS	PS	N/A	.3
		18 to 48	SC SBK	SEAP					
2	Linear 7%	0 to 14	SCL WSBK	SEAP FR	PS	PS	PS	N/A	.3
		14 to 39	C MSBK	SEAP FR	PS	PS			
		39+48	CL MSBK	SEAP FR					
3	Linear 5%	0 to 7	SL GR		Chroma 3 mot	PS	PS	N/A	.125
		7 to 20	C MSBK	SEAP FI					
		20 to 40	C MSBK						
4	Linear 4%	0 to 8	C SBK	SEAP FR	PS	PS	PS	N/A	.3
		8 to 48	SCL WSBK	NEAP FR					
5	Linear 5%	0 to 14	C SBK	SEAP FR	PS	PS	PS	N/A	.3
		14 to 48	SCL WSBK	NEAP FR					

AVAILABLE SPACE (.1945)_____SITE CLASSIFICATION (.1948):_____SITE LONG-TERM ACCEPTANCE RATE:
EVALUATED BY:_____OTHER(S) PRESENT:
COMMENTS: