4629-71-4115

0214

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

CONTRACTOR Jeff Hall DATE 9-1-89 PERMIT NO. D-

Owner's Name Home

Morrison Farm Rd TR Allendale Rd

3rd House on left. S. R. No.

SUBDIVISION Allendale Circle LOT NO. 3 SECTION OR BLOCK NO.

Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Character & Porosity of Soil Prev. Suitable

Heating Unit Yes ( ) No ( ) Percolation Rate 2


Dishwasher Yes ( ) No ( ) Topography Level

Washing Machine Yes ( ) No ( ) Depth to Water Table 18+

Other Yes ( ) No ( ) Rock or other impervious formations None

Bypass

Slab room with Plumbing ____ Basement without Plumbing ____ No Basement



Size of Tank 1500

Nitrification Field:

No. of Lines 3

Sq. Ft. 200 Linear Ft.

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public ( )

Installed by Donald Lee

I understand and agree to install septic system as specified on this improvement Permit.

Signed:

Date: 9-18-89

ICHD-Environmental Health Division

The proposed Pool & Pool House addition does not appear to impact the existing septic system.

**NOTE: Pool & Pool House is Existing & constructed

INSPECTED BY Steve Brown

DATE 9-1

DATE

COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATION

...made in installation of system and if any false information is supplied in making

Inspection Copy: Pink Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 25, 1989 20:28