DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN
REDELL
4629 71 9059

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: PATOKA HOUSING GROUP APPLICANT: TERRY PATOKA
ADDRESS: 12619 LONGSTOCK CT, HUNTERSVILLE APPLICATION DATE: 5-2-01 DATE EVALUATED: 6-2-01
PROPOSED FACILITY: 3BR MOD. HOUSE PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 0.5 ACRE
LOCATION OF SITE: ALLENDALE POINT #39 PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ~~☑ Auger Boring~~ ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 6%	0-48	GR LS SAPROLITE	VFR NEXP			PS		PS 0.6
2	L 6%	0-48	GR LS	VFR NEXP			PS		PS 0.6
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.6	0.6

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HOSKICK
OTHER(S) PRESENT: TERRY PATOKA