IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 $25.00 Paid MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 127412 PIN# 4629 72 6627

OWNER OR CONTRACTOR Steven Mitterhalter DATE June 14, 05

ADDRESS 13400 Glessner Pl. Huntersville, N.C. 28078 PHONE: Business (704) 200 - 8947 Home (704) 875 8625

LOCATION State Park Road TL Morrison Farm Rd. TL Wee Ski Way Lane on left

SUBDIVISION Crescent BLOCK / SECTION 17 LOT 25 LOT AREA .657AC SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 835 Date 4-25-06

Pump Tank: 1000 Gallons; PT 802 Date 4-20-06

Pump Make: Zoeller Model N-152 Serial No. ______

Nitrification Field: No Fields 1 Square Feet 534 Linear Feet 267

No Lines 6 Trench Width 24" min 8" oc Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, ⓘⓥ, V, VI

System Description: LPPPBPS

Repair System Description: partial LPPPBPS / platted NOV 75

Maintenance Agreement Required: ☒ Yes ☐ No

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms ___ No. Employees ___

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: 61 panels total. 1¼" sch 40 thru panels with one 3/16" hole per panel. Pump specs: 44 gal/min @ approx 38' TDH (3' pressure head calculated)

1" = 40'

Old Septic to be disconnected - Remove and properly dispose of if needed.

Comments:/Conditions: TUFFPDO Filter MARVOC, INSTALLER SHOWED ME PT, LINES 10' OFF LC

