IREDELL COUNTY HEALTH DEPARTMENT

THIS PERMIT VOIDS PREVIOUS ISSUED 11-10-97

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 0699781 PIN 4629 72 8987

OWNER OR CONTRACTOR DALLAS LYALL PHONE: Business Home (536) 924-5725 DATE 4-6-98

ADDR. ST 5626 BETHANIA ROAD

LOCATION US 21 S, LT FERTH, TR STATE PARK TL PFAFFTOWN, NC

SUBDIVISION MARKLAND FARM LOT 17 LOT 32 TL WILLOW POINT TR CROMDALE, 3RD LT ON LT

LOT AREA 0.80 ACRE SITE CLASS 1S DESIGN FLOW 360 I TAR 0.33 GAD/FT²

Septic Tank 1000 Gallons 1012 Date 3-3-98

Pump Type Gallons Date

Pump Make Model Date

Distribution Box No. 1 Square Feet 1080 Trench Feet 360

No Lines FOUR Trench Width 24" Trench Bottom Depth 36"

New System Repair System Type I II III IV V

System Description: CONVENTIONAL GRAVITY

Repair System Description: MAX. POSSIBLE TRENCHES

Maintenance Agreement Required Yes No

Gravel Depth 12

House/Mod. Home No. Bedrooms 3

Mobile Home No. Bathrooms 2

Business No. Employees

Other


Slab Crawl Space Basement w/plumbing Basement w/o plumbing

Water Supply: Individual Public Community WELL

Comments/Conditions: ① USE SMALL SYSTEM AS PLOTTED ON SITE ② KEEP SYSTEM MINIMUM 100' FROM WELL

Comments/Conditions:

INITIAL SITE SKETCH



The location of the proposed detached 28'x28' addition does not appear to impact the existing septic system. **NOTE: Keep min 5' off septic system

REHS

Date: 4-6-11

ICHD-Environmental Health Division

Installed as shown

IREDELL COUNTY HEALTH DEPT. ENVIRONMENTAL DIVISION 318 STATESVILLE HIGHWAY STATESVILLE, NC 28625 COURIER 09-36-07

I understand that this permit can be surrendered or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months

Signed [signature]

Improvement Permit by: STEVE HEDRICK date 4/6/98

Authorization to Construct by: STEVE HEDRICK date 4-6-98

Installed by Steve Jordan

Operation Permit by: Mark C Offord date 5-12-98

Existing System Inspection by: date

PROPERTY OWNER COPY (FINAL) GREEN OWNER COPY (FINAL) YELLOW INSPECTION COPY (INITIAL) PINK OWNER COPY (INITIAL) GOLD

JAN. 1, 1989 0:50