IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR E. O. Ledbetter DATE 8-12-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Potts Rd. in Troutman. T.R. on 1371. T.R. at Big Feeder Line. Trailer on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 158 SECTION OR BLOCK NO. 17


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes ( )	No (✓)
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Cecil Clay Loam
Percolation Rate _____
Topography Steep Slope to Lake
Depth to Water Table Unk
Rock or other impervious formations None

Lot Area 20,000 Sq ft +-



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by John Mercer

IMPROVEMENTS PERMIT BY _____

COMMENTS: Very important that surface water be diverted away from lines.
Well to be More Than 50' from any Part of Septic Tank System.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 8-12-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold