IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. D. Leopard DATE 6/26/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Perth Rd. at Troutman. T.R. on # 1321 T.R. at Big Power Line. 1st drive on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 173 SECTION OR BLOCK NO. 17

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area _____


Character & Porosity of Soil _____

Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____



Plot of System

Existing

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Henry Sigmon on 8/27/76

IMPROVEMENTS PERMIT BY _____

COMMENTS: Replacing Present Trailer with double wide. Block Patio will have to be taken down in order for double wide to go in. Trailer must not be placed over Septic Tank or lines. Existing system Working O.K. at this time

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/26/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold