13194

BOOK 41323

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

3C-11-A-90

OWNER OR CONTRACTOR Richard Ackerman DATE 10-25-91 PERMIT NO. 3C-11-A-90

PHONE: Business _____ Home _____

LOCATION Morrison Farm Rd off State Park Rd TR on 2nd St, Seakirk Dr. at end S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Addition to Ex. S.T. system


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Prev. Suitable
Percolation Rate 4 gal/sq ft/day
Topography 2 to 20%
Depth to Water Table 10'+
Rock or other impervious formations Heavy Formations of Rock in Excavation

Lot Area Ample

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank Ex. Gals.

Nitrification Field:
Addn No. of Lines 1
Sq. Ft. 200 Linear Ft. 100
Depth of Stone in Lines _____

Water Supply: Individual (✓)
Public ( )

T + J Panel system

Installed by E. J. Ervin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 10-25-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold