## IREDELL COUNTY HEALTH DEPARTMENT

### (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wm. M. Grubb DATE 8/9/99 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Perth Rd in Troutman. T.R. on 1321 - T.R. 2nd Rd Past Old Bussell Farm House. # Trailer on Rt. Near end of Rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 91 SECTION OR BLOCK NO. 18


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

| | | |
|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No ( ) |
| Auto. Dishwasher | Yes ( ) | No ( ) |
| Auto. Wash. Machine | Yes ( ) | No ( ) |
| Site Suitable | Yes ( ) | No ( ) |

Lot Area 20,000 Sqft

Character & Porosity of Soil Prov Suitable
Percolation Rate _____
Topography Steep Slope
Depth to Water Table Low
Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines _____
Sq. Ft. _____ Linear Ft. 110
Depth of Stone in Lines T + J 12 Inch Panels
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Jowers & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: Divert surface water away from septic Tank + lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8/9/99

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold