IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mrs Virginia M. Mills DATE 6-28-76 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Turn on Perth Rd at Troutman. T.R. on 1321 - Keep on 1330 T.R. on 1461 - Trailer on Rt. Past Fish & Game Club. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 120 SECTION OR BLOCK NO. 18

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Lake
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
Lot Area 0.79 Acre			Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Osteen

IMPROVEMENTS PERMIT BY _____

COMMENTS: Well to be More than 50' from Septic Tank + Lines.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6-28-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold