IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Mann DATE 3-9-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Peitz Rd at Troutman - T.R. on 1321 - Keep Straight on 1330. Tr. on 1461 - Trailer on R. Past Rudell Fish & Game Club. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 119 SECTION OR BLOCK NO. 18


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slope to Lake
Depth to Water Table Low
Rock or other impervious formations None

Lot Area 20 000 sq ft



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Ostwalt

IMPROVEMENTS PERMIT BY _____

COMMENTS: This tank was Called in 12:30 P.M. 3-9-76 - But due to a Mixup in Communications Was Not inspected by this department before it was Covered.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-9-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold