873-7241

SITE EVALUATION

(Ground Absorption Sewage Disposal)

ER: TOM ROBERTS DATE REQUESTED: 8-8-83

RESS: Rt 4 Box 68, HUNTERSVILLE, N.C. PLAT NO.: LOT 98 at SECTION 1B

NTY: IREDELL LOT SIZE: .65 acre

ATION OF SITE: OFF MORRISON FARM RD. - T.R. on SEAKIRK DRIVE 1st (MINNICK SIGN). LOT ON RIGHT AT 1st DRIVEWAY.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
SLOPE (%)	S (PS) U	S (PS) U	S PS U	S PS U
SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1 clay)	S (PS) U CLAYEY BLOCKY	S (PS) U CLAYEY BLOCKY	S PS U	S PS U
SOIL STRUCTURE (12-36 in.) (Clayey soils)	S (PS) U	S (PS) U	S PS U	S PS U
SOIL DEPTH (In.)	S (PS) U	S (PS) U	S PS U	S PS U
RESTRICTIVE HORIZONS (In.) (Impervious Strata, rock)	(S) PS U	(S) PS U	S PS U	S PS U
SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) PS U	(S) PS U	S PS U	S PS U
SOIL PERMEABILITY (Percolation Rate)	S (PS) U	S (PS) U	S PS U	S PS U
OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
SITE CLASSIFICATION*	Provisionally Suitable	Provisionally Suitable		
SOIL SERIES				

S - Suitable PS - Provisionally Suitable U - Unsuitable

ee Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc.)

ommendations/Comments: Stay off Lake at least 50' with Septic + off property lines at least 15'

cribed By: Steve Brewer

Title: Sanitarian Date: 8-8-83

Form 2601 (2/77)
itation