IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David H. Harmon DATE 10/7/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Perth Rd at Troutman, T.R. on Rd 1321 T.R. into Morrison Point. Beside Big Red House on L S. R. No. _____

SUBDIVISION NAME Morrison Point LOT NO. 10 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 175 X 200


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slope to lake Low

Depth to Water Table _____

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

From Tatum well

Installed by Sam Ostwalt

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from downspouts should be diverted away from septic tank + lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 10/7/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold