IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles Dockery DATE 3/17/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Perth Rd at Troutman. T.R. on State Park Rd #1321 T.L. on #1415. House on L. S. R. No. _____

SUBDIVISION NAME Happiness Lane LOT NO. 16 SECTION OR BLOCK NO. 17


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 Sq ft +

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Steep Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: Good Soil – All surface water possible should be diverted away from Tank + Lines.

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 3/18/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold