IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 157497 PIN # 4629-81-7898 DATE 12 August 09

OWNER or APPLICANT Tom Kiser PHONE: Business (910) 624-3424 Home: (910) 678-9616

OWNER or APPLICANT ADDRESS 2008 Winterlochen Rd. Fayetteville, NC. 28305

LOCATION / DIRECTIONS Perth Rd. TR State Park Rd. TL Morrison Farm Rd. TL Butternut. House on Left

SUBDIVISION BLOCK / SECTION LOT # LOT AREA 1.3ac. DESIGN FLOW 600g/d L.T.A.R. 0.3g/sf/d

Septic Tank	1500	Gallons: STB	444	Date	4-4-11	☑ New System ☐ Repair ☐ Expansion System	Type I II III (IV) V VI
Pump Tank	1500	Gallons: PT	477	Date	3-11	System Description: 50% Reduction - LPP distribution	
Pump Make		Model		Serial #		Repair System Description: 50% Reduction. LPP distribution	
Nitrification Field	No Fields 1	No Lines	5	Linear Feet	340	Maintenance Agreement Required ☑ YES ☐ NO	
Trench Width	24"	Max. Trench Bottom Depth	36"	Gravel Depth	NA	☐ GRAVITY ☑ PRESSURE	

☑ Residence No. Bedrooms 5 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☑ Private ☐ Public ☐ Community

Comments / Conditions
* Well permit has not yet been applied for.
* System area approximate. Final location of septic system and pump sizing will be determined when actual house footprint and plumbing elevations are located in the field.

Comments / Conditions

INITIAL SITE SKETCH

* Please see attached site sketch.
* 50% Reduction System with LPP distribution to be installed According to manufacturers specifications.
* Honor all setback requirements.
* All wells and existing septic system to be properly Abandoned before construction of system.

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☑ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Kristi Van Hoy Date 8/12/09

Improvement Permit by: [signature], R.S. Date 12 August 09

Authorization to Construct by: [signature], R.S. Date 26 OCT. 10

Installed by: R&H

Operation Permit by: [signature] Date: 9-9-12

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant

4/c → [signature] Date 10/26/10