IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 211356

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4629830895

APPLICANT: Live Well Homes APPLICANT ADDRESS: 501 Spring Crest Dr.

SITE ADDRESS: 636 Stillwater Rd. PHONE: 704-578-4951 ALT. PHONE: N/A

SITE DIRECTIONS: State Rock Rd to Morrison Farm Rd. TL Stillwater Rd.

SUBDIVISION: Falls Park SECTION: 3A LOT # 35 LOT AREA: 2.2 acres DESIGN FLOW: 480 gpd L.T.A.R.: 0.25

Septic Tank	1000 (gal)	STB	Infiltrator	Date	Im-1060	☑ New System	☐ Repair	☐ Expansion	System Type: I II (III) IV V VI	☑ Residence	No. Bedrooms 4
Pump Tank	(gal)	PT		Date		System Description:	25% Reduction			☐ Business	No. Persons 8
Pump Make		Model		Serial #		Repair System Description:	25% Reduction			☐ Other	No. Employees
# Nitrification Fields	1	# Lines	4	Linear Ft:	480	Maintenance Agreement Required:	☐ YES	☑ NO		☐ Slab	☑ Crawl Space
Trench Width	36"	Max. Trench Bottom Depth	36"	Gravel Depth	N/A		☑ GRAVITY	☐ PRESSURE		☐ Basement w/plumbing	☐ Basement w/o plumbing

Water Supply: ☐ Private ☑ Public ☐ Community

Comments / Conditions: * Install trench bottoms @ 36" on high side *

INITIAL SITE SKETCH

See attached design by:

Kathleen Saunders, LSS

AS BUILT SKETCH

- Red Polylok filter installed
- Infiltrator Plastic ST Installed
- Quick 4 chambers installed on high side
- 1250 gal Tank installed

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☑ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 8-6-15

IMPROVEMENT PERMIT by: Justin Henderson Date: 8-5-15

AUTHORIZATION TO CONSTRUCT by: Justin Henderson Date: 8-5-15

Installed by: Wesson Septic Tank Service

OPERATION PERMIT by: Justin Henderson Date: 2-16-16

Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

WATER ROAD
60' PUBLIC R/W
25' FRONT YARD
EXISTING TREELINE, TYP.
House
Box - 6C2
Driveway
104'
36
47,482 SF
1.779 AC
Box Lines