DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Lee Eaton
ADDRESS: ___
APPLICANT: ___
APPLICATION DATE: ___
PROPOSED FACILITY: SFR
PROPOSED DESIGN FLOW (.1949): 360 GPD
DATE EVALUATED: 5-14-98
LOCATION OF SITE: Willow Ct NE to end on Right Lot 3
PROPERTY SIZE: ___
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other ___
PROPERTY RECORDED: No
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	L 9-10%	0-7	gr hcnsl/scl	fr					.5+
		7-13	smb RCL	fr ss so					
		13-48	msmb RCL	fr ss so 1:1					
2	L S-MOD ERODED 10-15%	0-6	smb R hcnsl/scl	fr ss so 1:1					.5+
		6-19	smb R-y CL	fr ss so 1:1					
		19-48	msmb R-y scl/cl	fr ss-ns sp					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___