HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Thomas Loftin OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 4-11-94
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE:
LOCATION OF SITE: Stillwater
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	3-5% L	0-4"	l	gr.	1:1 / vfr	.1942 WETNES CONDITION	P.S.
		4"-48"	c	sbk	1:1 / fr	.1943/.1556 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
2	3-5% L	0-6"	l	gr	1:1 / vfr	.1942 WETNES CONDITION	P.S.
		6"-42"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE	42"-↑ c/sap.
		42"-↑	c/sap mix			.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
3	3-5% L	0-7"	L	gr	1:1 / vfr	.1942 WETNESS CONDITION	P.S.
		7"-48"	c	sbk.	1:1 / fr	.1943/.1956 SAPROLITE	NA
						.1944 RESTRICTIVE HORIZON	NA
						.1948 PROFILE CLASSIFICATION	P.S.
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S. SITE LONG-TERM ACCEPTANCE RATE: .35 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE conventional, gravity fed
EVALUATED BY: Michael J. Dorsett OTHER(S) PRESENT: Tommy Loftin.
COMMENTS:

DRAFT

0010332