IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Brady L. Ward Clarence Poole DATE 5/30/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Poth Rd at Troutman. T.R. on 1321. T.L. just before big Power Lines. Been To R. Trailer on L. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. 58 SECTION OR BLOCK NO. 17

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area 0.84 acre

Character & Porosity of Soil Cecil Clay


Percolation Rate _____

Topography Slope to Lake

Depth to Water Table Low

Rock or other impervious formations None

Existing Trailer



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Joe Parlier well

Installed by Self.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trailer will need to be jacked up approx 8" to allow fall from Trailer to Tank

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5/30/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold