DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet
PROPERTY ID #
COUN

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: DAVID STONE APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	16% L	0-4"	scl, wk, gr	fr, ss, sp, sexp					PS .3
		4-16"	C, med, sbk	fr, ss, sp, sexp					
		16-38"	C, med, sbk	fi: com/many sap inclusions ss, sp, sexp					
		38-60"	loamy sap	fr, ns, np, mexp					
2	16% L	0-24"	Cl, med, sbk	fr, ss, sp, sexp					PS .4
		24-60"	loamy sap, wk, sbk	fr, Cl inclusions ss, sp, sexp					
3	20% LSS	0-24"	Cl, med, sbk	fr, ss, sp, sexp					PS .3
		24-48"	loamy sap	fr, ns, np, mexp					
4	20% LSS	0-4"	scl, wk, gr	fr, ss, sp, sexp					PS .3
		4-38"	C, mscl, sbk	fr/fi: sap in clus ss, sp, sexp					
		38-60"	loamy sap	fr, ns, np, mexp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	PUMP PANEL	LP PANEL
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: _____