DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:_____
DATE:_____
COUNTY:_____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Crescent Properties
ADDRESS:_____
OWNER___AGENT:___PHONE:_____
APPLICATION DATE:_____ DATE EVALUATED 11-4-95
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE:_____
WATER SUPPLY: On-site Well____ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring___ Pit ✓ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	~20 %	0-8"	l	gr	1:1			.1942 Wetness Cond. -
	L	8"-24"	c	sbk	1:1			.1943 Depth/.1956 Sapr. -
		24"-36"	c/sap.	wsbk/m	1:1			.1944 Restrictive Hori. -
		36"-48"	sap.			Sap ribboned over 1"		.1948 Profile Class. -
								Profile LTAR -
2		0-5"	l	sr				.1942 Wetness Cond. -
		5"-18"	c	wsbk				.1943 Depth/.1956 Sapr. -
		18"-30"	c/sap	wsbk/m				.1944 Restrictive Hori. -
		30"-60"	sap (sl)			reclass. Fluid at 60" or below		.1948 Profile Class. -
								Profile LTAR -
3		0-5"	l	gr	fr.			.1942 Wetness Cond. -
		5-48"	C	SBK	FI			.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR - .3
4		0-8"	l	Gr	fr.			.1942 Wetness Cond. -
		8-42"	C	SBK	FI			.1943 Depth/.1956 Sapr. -
		42-48"	C-sap	WSBK	FI			.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR - .3

AVAILABLE SPACE (.1945)_____ OTHER FACTORS (.1946)_____ SITE CLASSIFICATION (.1948)_____

SYSTEM TYPE_____ LONG-TERM ACCEPTANCE RATE(S)_____

EVALUATED BY: Michael Dennis Jack Moore Joe Lynn OTHER(S) PRESENT:_____

COMMENTS: Soils were evaluated in area where LPP system is to be installed. Due to depth of soils LPP system was designed by Tim Whitaker