IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Robertson DATE 5-6-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Pertz Church Rd in Troutman - T.R. on #1321 - T.L. on 1447. Go ½ mile. Trailer on L. in Sharp Curve S. R. No. 1447

SUBDIVISION NAME _____ LOT NO. 9 SECTION OR BLOCK NO. 18

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area _____

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table Existing System
Rock or other impervious formations _____

Lake



Plot of System Road

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines _____
Water Supply: Individual (✓)
Public ( )

Installed by Sam Ostwalt
Put in 4-11-73

IMPROVEMENTS PERMIT BY _____

COMMENTS: This is an existing System and shows no signs of surfacing at this time. Appears to be working O.K.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5-6-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold