IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Melvin Arey DATE 8/5/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on Rusty Rd in Troutman - T.R. on 1321 - T.L. on 1447 Go approx 1/10 mile - Trailer on L. Just sharp curve S. R. No. 1447

SUBDIVISION NAME _____ LOT NO. 6 SECTION OR BLOCK NO. 18


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil Clay
Percolation Rate _____
Topography Slope to lake
Depth to Water Table Low
Rock or other impervious formations None

Lot Area 20,000 sq ft



Plot of System RL # 1447

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Yountz & Son

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trailer not on lot at time of inspection - Small building now on lot to be moved.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8/5/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold