HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tom Goodson OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 5-11-94
PROPOSED FACILITY: 4 Bedroom house
PROPERTY SIZE:
LOCATION OF SITE: Still water Rd.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit ✓ Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	0-2% L	0-7"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION - PS
		7"-48"	c	Sbk	1:1 / fr	.1943/.1956 SAPROLITE - S
					Slightly sticky	.1944 RESTRICTIVE HORIZON - S
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
2	1-3% L	0-8"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION - S
		8"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE - S
						.1944 RESTRICTIVE HORIZON - S
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
3	Augar 1-3%	0-5"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION - P.S.
		5"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE - S
					Slightly sticky	.1944 RESTRICTIVE HORIZON - S
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3
4	Augar 2-4%	0-5"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION - S
		5"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE - S
						.1944 RESTRICTIVE HORIZON - S
						.1948 PROFILE CLASSIFICATION - P.S.
						PROFILE LTAR - .3
5	Front yard Augar 3-5% L	0-7"	l	gr	1:1 / vfr	.1942 WETNESS CONDITION - P.S
		7"-48"	c	sbk	1:1 / fr	.1943/.1956 SAPROLITE - S
					Slightly Sticky	.1944 RESTRICTIVE HORIZON - S
						.1948 PROFILE CLASSIFICATION - P.S
						PROFILE LTAR - .3

AVAILABLE SPACE (.1945) P.S. SITE CLASSIFICATION (.1948): P.S SITE LONG-TERM ACCEPTANCE RATE: .3 gpd/ft²
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: Michael Q. Denson OTHER(S) PRESENT: David & Andy Younte, Tom Goodson.
COMMENTS: add 1 bedroom, 1 Bathroom, 1 office. Existing system completely saturated, Permitted system to accomadate all 4 bedrooms. (Panels:) No repair area not required, maximum feasable repair in front yard.

DRAFT