IREDELL COUNTY HEALTH DEPARTMENT 4634591645

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jim Hamilton DATE 8/13/79 PERMIT NO. 285

PHONE: Business _____ Home _____

LOCATION 1155 TR 1102

S. R. No. _____


SUBDIVISION NAME Sailor's Lair LOT NO. 30 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	40 min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	7-20%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	3' to 4' to Lake level	
			Rock or other impervious formations	NONE	

Lot Area 1 acre ±



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Orbison

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer + J. C. Moore DATE 8/13/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold