IREDELL COUNTY HEALTH DEPARTMENT 4634591710

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mady Const. DATE 9-18-78 PERMIT NO. 227

PHONE: Business _____ Home _____


LOCATION 1153 TR. on 1102

SUBDIVISION NAME Sailor's Fair S. R. No. _____ LOT NO. 29 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	—
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	20%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	5-6'
Lot Area 3/4 Ac.			Rock or other impervious formations	none obs.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"+
Water Supply: Individual (✓)
Public ( )

Installed by Blake Hyde
Mck. Co.

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 9-18-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold