4634597 5 T1

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wilfred Vermeulen DATE April 14, '88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 S. TR 1102 (Longtree) at end TR Schooner Dr. 1st house on left past Teakwood S. R. No. _____

SUBDIVISION NAME Sailor's Lair LOT NO. 34 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair


No. Bedrooms 4 No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	

Character & Porosity of Soil clay
Percolation Rate 3-40
Topography 2-4%
Depth to Water Table 81"
Rock or other impervious formations none obs.

Lot Area Existing

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 9 x 100' Bed
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Rodney Ellis

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

The proposed / ~~existing~~ Patio 14' x 22' addition does not appear to impact the existing septic system.
**NOTE: _____

Judy Melville REHS
Date: 6-1-10
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY _____ DATE 4-14-88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold