IREDELL COUNTY HEALTH DEPARTMENT ~~4635~~ 4634599790

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edward Agasian DATE 7-26-83 PERMIT NO. 248

PHONE: Business _____ Home _____

LOCATION 1102 TR 1286 3rd Lot on Rt. past Tankwood Drive

SUBDIVISION NAME Sailors Lair LOT NO. 16 S. R. No. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20000 ft²

Character & Porosity of Soil clay loam
Percolation Rate .16
Topography 6-8%
Depth to Water Table 44
Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. ~~1200~~ Linear Ft ~~360~~ 400
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Jackson & Bennett Inc

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

Tank checked by D. Jamison - 7-26-83

CERTIFICATE OF COMPLETION BY Manifold checked by T. Cranmer 7-25-83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edward Azarian DATE 1-13-83 PERMIT NO. 10

PHONE: Business _____ Home _____


LOCATION 1102 TR Schooner Lane past 1st Intersection 3rd lot on R

SUBDIVISION NAME Sailor's Lair LOT NO. 16 SECTION OR BLOCK NO. _____ S. R. No. _____

House (X) Mobile Home ( ) Business ( ) Other Outbuilding

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	Character & Porosity of Soil	
Auto. Dishwasher	Yes (X)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (X)	No ( )	Topography	Existing
Site Suitable	Yes (X)	No ( )	Depth to Water Table	System
Lot Area Existing			Rock or other impervious formations	



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines Existing
Sq. Ft. _____ Linear Ft. _____
Depth of Stone in Lines _____

Water Supply: Individual (X)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY JW Tyler

COMMENTS Slab of Outbuilding too close to Nitrification field (< 1 ft)

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Fred Clemmer DATE 1-13-83

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold